



Henry A. McCandless
Vice President, Manufacturing

EPA Region 5 Records Ctr.



298177

Amoco Petroleum Additives Company

Post Office Box 182
Wood River, Illinois 62095-0182
618-251-2200

December 6, 1984

119 115 AAA

Mr. Jeff Benbenek
Division of Air Pollution Control Field Office
Illinois Environmental Protection Agency
115A West Main Street
Collinsville, Illinois 62234

Dear Sir:

Insulation of Amoco DEA Line

During the 1983-84 winter, an outage was experienced on Amoco's H₂S Removal System at the Multi-Purpose Additives Plant. The outage was the result of freezing the circulating DEA line between Amoco and Shell and was reported to your office in a letter dated February 17, 1984. In that correspondence it was promised that the line would be insulated to prevent the recurrence of the freezing problem. We are hereby notifying you of the completion of the insulation work and fulfillment of our pledge.

With extreme cold weather upon us, we are anticipating the additional freeze protection to afford us much more trouble-free operation of the H₂S Removal System than was experienced the past winter.

Yours truly,

Henry A. McCandless

RAS/de

CC: DAPC CENTRAL FILE

REGION III, DAPC

RECEIVED
Environmental Protection Agency

DEC 10 1984

115A W. MAIN ST.
COLLINSVILLE, ILL